

**ELEMENT TABLE**

ANALYTE	RESULTS	UNITS	SRL	AL	MCL	LIKELY POTENTIAL SOURCE OF CONTAMINATION
<b>FEDERALLY REGULATED</b>						
Arsenic	0.0017	mg/L	0.002	0.0005	0.05	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium	0.0036	mg/L	0.0002	2	2	Discharge of drilling wastes; discharge from metal refineries erosion of natural deposits.
Cadmium	ND	mg/L	0.0002	0.005	0.005	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries runoff from waste batteries and paints.
Chromium	ND	mg/L	0.001	0.1	0.1	Discharge from steel and pulp mills; erosion of natural deposits
Nitrate-N * 8/16/2012	.05J	mg/L	0.5	0.05		1 Runoff from fertilizer use;
	.05J	mg/L	0.2	N/D		10 Leaching from septic tanks
<b>FEDERALLY REGULATED (Secondary)</b>						
Iron	0.2	mg/L	0.1	0.3	0.3	
Manganese	0.045	mg/L	0.0002	0.05	0.05	
Sulfate	10	mg/L	0.5	250	250	
Zinc	N/D	mg/L	0.005	5	5	
<b>STATE REGULATED</b>						
Sodium	22	mg/L	1			
Hardness	56	mg/L	0.05			
Turbidity	0.28	NTU	0.05	1	1	
<b>STATE UNREGULATED</b>						
Lead	0.0007	mg/L	0.0002	0.015		
Copper	0.58	mg/L	0.02	1.3		
<b>OTHER</b>						
Magnesium	4.9	mg/L	0.1			
Calcium	14	mg/L	0.1			

This table shows all detections for the reporting period. THESE ARE NOT VIOLATIONS. Only a constituent with results exceeding the AL under the Federally Regulated category would be a violation. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water hotline at 1-800-426-4791.